

Pressure Sustaining Valve



FAILURE

VALVE FAILS TO OPEN

POSSIBLE CAUSE

Wrong tubes connection

The 3-way selector is in the CLOSE position

Low upstream pressure

Faulty pilot

SOLUTION

Compare with connection diagrams and correct

Verify knob position on AUTO

Increase upstream pressure according the design

Debris in pilot, dismantle, clean or replace

FAILURE

VALVE FAILS TO CLOSE

POSSIBLE CAUSE

Wrong tubes connection

Damaged diaphragm

Faulty pilot

SOLUTION

Compare with connection diagrams and correct

Turn 3-way selector to port OPEN, if water flows constantly - replace diaphragm

Debris in pilot, dismantle, clean or replace